

HIMACHAL PRADESH Load Despatch Society.

No.HPLDS/A&R/SLDC-44/2018-19 - 1126-27

Dated: 3/7/18


To

The Chief Manager, NORTHERN REGIONAL LOAD DESPATCH CENTRE
18-A, SHAHEED JEET SINGH SANSANWAL MARG, KATWARIA SARAI,
Fax No.011-26852747

The S.E. (Operation)
NRPC, 18-A, Qutab Institutional Area,
Shaheed Jeet Singh Marg,
Katwaria Sarai, New Delhi-110 016
Fax No.011-26865206

Subject: Own Generation, Availability & Requirement for the month of June, 18

A.	ENERGY AVAILABILITY/REQUIREMENT IN Mus (EX BUS)	
1	OWN GEN	
	HYDRO	233.70
	IPPs	118.361
	Baspa	224.216
	THERMAL	0.00
	TOTAL	576.28
2	DEDICATED PROJECTS	0.00
	BTPS (100 %)	0.00
	FARIDABAD GAS	0.00
	RAPP (A) 100 %	0.00
	TANDA 100 %	0.00
	Total Own gen. & Dedicated	576.28
3	Drawal from Grid	254.280
4	Net Availability after banking/sale of power	830.56
5	Rrestricted Requirement	780.36
6	Shortage(-)/Surplus (+)	50.20
7	%age Shortage(-)/ Surplus (+)	6.43
8	Unrestricted Requirement	782.27
9	Shortage(-)/Surplus (+)	48.28
10	%age Shortage(-)/ Surplus (+)	6.17
B	THE DETAILS OF CALCULATIONS	
1	AVAILABILITY	830.56
2	AVAILABILITY MU/day	27.69
3	LOAD SHEDDING & POWER CUTS	1.916
4	UNRESTRICTED REQUIREMENT	782.274
5	REQUIREMENT MU/DAY	26.08
C	DEMAND AVAILABILITY / UNRESTRICTED REQUIREMENT (EX BUS) IN (MW)	
1	PEAK REQUIREMENT UN- RESTRICTED	1474.00
3	PEAK AVAILABILITY	1408.00
4	SHORTAGE/Surplus (-)/(+)	-66.00
5	%age Shortage(-)/ Surplus (+)	-4.69


 Chief Engineer, SLDC
 HP Load Despatch Society,
 Totu, Shimla-11.

Max demand Un-restricted 1474 on 08.06.2018 at 09.30hrs by overdrawl of 66 MW from grid